

BME | ASSOCIATES

ENGINEERS • SURVEYORS • LANDSCAPE ARCHITECTS

October 13, 2015

Mr. Adam Cummings, PE
Barton & Loguidice PC
11 Centre Park
Rochester, New York 14614

**Re: Lago Resort & Casino
July 2015 Amended and Restated Site Plan Review
Response to Comments**

2392A

Dear Adam:

We have prepared responses to your September 24, 2015 memorandum, addressed to Supervisor Ron McGreevy, regarding the Lago Resort & Casino Amended and Restated Site Plan Review. We have provided your original comment with our responses immediately following in bold lettering:

Plan Sheet comments:

1. **Sheet 15** – There is a note referencing as Sanitary Dumping Station. Please clarify this note and provide adequate details of its design. If this station is not proposed, please confirm.

The sanitary sewer dumping station is not proposed.

2. **Sheet 22** – The plans show that the two existing groundwater wells will be abandoned. Please clarify that these wells will not only be abandoned, but will also be decommissioned in accordance with NYSDOH requirements.

The two existing groundwater wells will be decommissioned in accordance with the New York State Department of Health (NYSDOH) requirements and regulations. The Town will be copied on applicable correspondence from the NYSDOH once the decommissioning process of the wells has been completed.

Please feel free to contact our office with you any questions you may have in this regard.

Thank you.

Sincerely,
BME Associates

A handwritten signature in black ink, appearing to read "James G. Cretekos". The signature is fluid and cursive, with a large initial "J" and "C".

James G. Cretekos, P.E.

JGC

c: Ronald McGreevy, Supervisor; Town of Tyre
Virginia Robbins, Esq.
John Mancuso, Esq.
James McKenna; Wilmorite, Inc.