

## Robbins, Virginia

---

**From:** Metivier, Steven V LRB <Steven.V.Metivier@usace.army.mil>  
**Sent:** Thursday, June 05, 2014 11:21 AM  
**To:** Martin Janda  
**Cc:** Robbins, Virginia; Mike Simon  
**Subject:** RE: Wilmot Casino (UNCLASSIFIED)

Classification: UNCLASSIFIED  
Caveats: NONE

Thanks Martin. When I get these submissions, sometimes it's not clear whether or not a report is coming to us, so I try and be as thorough as possible in my responses.

I look forward to receiving the report.

Steve

-----Original Message-----

**From:** Martin Janda [<mailto:MJanda@bmepec.com>]  
**Sent:** Thursday, June 05, 2014 11:19 AM  
**To:** Metivier, Steven V LRB  
**Cc:** [RobbinV@bsk.com](mailto:RobbinV@bsk.com); Mike Simon  
**Subject:** [EXTERNAL] FW: Wilmot Casino

Hi Steve,

This is in response to your email you sent to Ms. Robbins from May 29th, 2014.

Your comments/observations are addressed as follows:

1. The wetland delineation was completed according to the updated 2012 guidelines for Northeast region. We are in a process of completing wetland delineation report which we will submit to you and NYSDEC and request a site meeting with your department.
2. The drainage swale is the result of construction of Petro gas station south of Thruway and large pavement areas associated with that. Petro site was build several years ago and drains on our site without much of stormwater treatment. The area within the casino site that the Petro stormwater seasonally drains to is an active agriculture field. Stormwater settles within the fields in several depressions where it eventually infiltrates. The several of the wetland areas are actively farmed every year. The drainage path from Petro and Thruway is not well defined.
3. See response # 2.
4. We laid this site out to purposely avoid wetlands as much as possible. We completely avoided wooded wetlands to the east and the woods buffering them.

Thanks for your comments. We will be submitting *our report* soon.

Martin

Classification: UNCLASSIFIED

Caveats: NONE