

SENECA COUNTY DEPARTMENT OF HEALTH
 - *Division of Environmental Health Services* -
 31 THURBER DRIVE
 WATERLOO, NEW YORK 13165
 (315) 539-1945

RECEIVED
 JAN - 9 2015
 BME ASSOCIATES

January 8, 2015


BME Associates
 James Cretekos
 10 Lift Bridge Lane East
 Fairport, NY 14450

Dear James:

Enclosed please find the plan approval for the water main extension to serve the Lago Resort and Casino project. I have also enclosed two of the three sets of approved plans for your use. The Seneca County Department of Health will reserve one set of the plans for its records.

If you have any questions, please feel free to contact me at 315-539-1947.

Sincerely,



Thomas E. Scoles
 Principal Sanitarian

Approval of Plans for Public Water Supply Improvement

This approval is issued under the provisions of 10 NYCRR, Part 5:

1. Applicant Whitetail 414, LLC	2. Location of Works (C, V, T) Tyre (T)	3. County Seneca	4. Water District (Specific Area Served) No. 1, NYS Route 414
5. Type of Project <input type="checkbox"/> 1 Source <input type="checkbox"/> 3 Pumping units <input type="checkbox"/> 5 Fluoridation <input checked="" type="checkbox"/> 7 Distribution <input type="checkbox"/> 2 Transmission <input type="checkbox"/> 4 Chlorination <input type="checkbox"/> 6 Other Treatment <input type="checkbox"/> 8 Storage <input type="checkbox"/> 9 Other			
Remarks: Installation of approximately 555 feet of 12-inch PVC SDR 18 and approximately 295 feet of 12-inch HDPE DR 17 water main extending under the NYS Thruway to the proposed Lago Resort and Casino development. SENECA COUNTY NOV 26 2014 ENVIRONMENTAL HEALTH			


By initiating improvement of the approved supply, the applicant accepts and agrees to abide by and conform to the following:

- THAT the proposed works be constructed in complete conformity with the plans and specifications approved this day or approved amendments thereto.
- THAT the proposed works not be placed into operation until such time as a Completed Works Approval is issued in accordance with Part 5 of the New York State Sanitary Code.
- THAT the proposed works be constructed in accordance with all applicable Federal, State and local regulations.

ISSUED FOR THE STATE COMMISSIONER OF HEALTH

Date:

11/26/14

 P.E.

Designated Representative
Jeffrey A. Rowe, P.E.
Consulting Engineer

General

6. Type of Ownership <input checked="" type="checkbox"/> Municipal <input type="checkbox"/> Commercial <input type="checkbox"/> 68 Private – Other <input type="checkbox"/> 1 Authority <input type="checkbox"/> 30 Interstate <input type="checkbox"/> Industrial <input type="checkbox"/> 9 Water Works Corp. <input type="checkbox"/> Private – Institutional <input type="checkbox"/> 19 Federal <input type="checkbox"/> 40 International <input type="checkbox"/> 18 Indian reservation <input type="checkbox"/> 26 Board of Education <input type="checkbox"/> 20 State		
7. Estimated Total Cost \$105,000	8. Population Served N/A	9. Drainage Basin N/A
10. Federal Aid Involved? <input type="checkbox"/> 1 Yes <input checked="" type="checkbox"/> 2 No		11. WSA Project? <input type="checkbox"/> 1 Yes <input checked="" type="checkbox"/> 2 No

Source

12. <input type="checkbox"/> Surface Name: N/A Class: N/A <input type="checkbox"/> Ground Name: N/A Class: N/A	13. Est. Source Development Cost N/A
14. Safe Yield N/A	15. Description: N/A

Treatment

16. Type of Treatment <input type="checkbox"/> 1 Aeration <input type="checkbox"/> 4 Sedimentation <input type="checkbox"/> 7 Iron Removal <input type="checkbox"/> 10 Softening <input type="checkbox"/> 2 Microstrainers <input type="checkbox"/> 5 Clarifiers <input type="checkbox"/> 8 Chlorination <input type="checkbox"/> 11 Corrosion Control <input type="checkbox"/> 3 Mixing <input type="checkbox"/> 6 Filtration <input type="checkbox"/> 9 Fluoridation <input type="checkbox"/> 12 Other			
17. Name of Treatment Works N/A	18. Max. Treatment Capacity N/A	19. Grade of Plant Operator Req. N/A	20. Est. Cost N/A
21. N/A			

Distribution

22. Type of Project Distribution Mains <input type="checkbox"/> 1 Cross Connection <input checked="" type="checkbox"/> 2 Interconnection <input checked="" type="checkbox"/> 3 Transmission <input type="checkbox"/> 4 Fire Pump Cl ₂	23. Type of Storage Elevated <u> N/A </u> gallons Underground _____ gallons	24. Est. Distribution Cost \$105,000
25. Anticipated Distribution System Demand: <u> 0.145 </u> MGD Max. <u> 0.290 </u> MGD		26. Designed for fire flow? <input checked="" type="checkbox"/> 1 Yes <input type="checkbox"/> 2 No
27. Description Installation of approximately 555 feet of 12-inch PVC SDR 18 and approximately 295 feet of 12-inch HDPE DR 17 water main extending under the NYS Thruway to the proposed Lago Resort and Casino development.		